

| | A | B | C | D | E |
|----|-----------------------|---|---------------------|---------------|----------------|
| 1 | HW-03 (Week 4) | | | | |
| 2 | Ex. 6-P11 | | | | |
| 3 | | Analyte | | Result | Trigger |
| 4 | | methane | Wellhead | 15,000 ug/L | 28,000 ug/L |
| 5 | | | Wellhead - dup | 28,000 ug/L | |
| 6 | | | | | |
| 7 | EPA Alt. Water | No | | | |
| 8 | Cabot Alt. Water | No-Have a water buffalo, Cabot previously provided water | | | |
| 9 | | Sierra Club and others also provided water; if nec, pump from nearby creek | | | |
| 10 | Treatment | No-However, the well (located in basement) is vented to outside | | | |
| 11 | Proposed EPA Water | ? | | | |
| 12 | Proposed 2nd Sampling | ? | | | |
| 13 | HW-57 (Week 4) | | | | |
| 14 | Ex. 6-P11 | | | | |
| 15 | | Analyte | | Result | Trigger |
| 16 | | iron | Wellhead | 11,200 ug/L | 11, 000ug/L |
| 17 | | | Wellhead -filtered | U @100 ug/L | |
| 18 | | | Tap | U @100 ug/L | |
| 19 | | | Tap - filtered | U @100 ug/L | |
| 20 | | | | | |
| 21 | | Arsenic | Wellhead | 5.8 ug/L | 4.5 ug/L |
| 22 | | | Wellhead - filtered | U @1 ug/L | |
| 23 | | | Tap | U @ 1ug/L | |
| 24 | | | Tap - filtered | U @ 1ug/L | |
| 25 | EPA Alt. Water | No | | | |
| 26 | Cabot Alt. Water | No-Per survey,Cabot previously provided water;reconditioned well in 2010 | | | |
| 27 | Treatment | Yes-filter installed on well bladder in 2010 (not certain what type of filter?) | | | |
| 28 | Proposed EPA Water | ? | | | |
| 29 | Proposed 2nd Sampling | ? | | | |
| 30 | | | | | |
| 31 | HW-60 (Week 5) | | | | |

| | A | B | C | D | E |
|----|-----------------------|--|---------------|---------------|----------------|
| 32 | Ex. 6-PII | | | | |
| 33 | | Analyte | | Result | Trigger |
| 34 | | Arsenic | Wellhead only | 9.3 ug/L | 4.5 ug/L |
| 35 | | Lithium | Wellhead only | 47.7 ug/L | 31 ug/L |
| 36 | | (lithium QL 5th week =25 ug/L) | | | |
| 37 | EPA Alt. Water | No | | | |
| 38 | Cabot Alt. Water | No - Per survey, is a weekend home and use bottled water when there | | | |
| 39 | Treatment | No | | | |
| 40 | Proposed EPA Water | ? | | | |
| 41 | Proposed 2nd Sampling | ? | | | |